

NOTES:

1. ALL CONFLICT MANHOLES TO BE APPROVED BY THE LOCALITY PRIOR TO THEIR USE.
2. FOR USE ON STORM DRAIN SYSTEMS 36" OR LESS IN DIAMETER AND WHEN THE CONFLICTING GRAVITY SEWER DOES NOT EXCEED 18" IN DIAMETER. ALL OTHER SITUATIONS REQUIRE A SPECIAL DESIGN AND LOCALITY APPROVAL.
3. SHADED AREA MUST EQUAL 1.5 (MIN.) TIMES THE CROSS SECTION AREA OF THE STORM DRAIN.
4. LOWER MANHOLE INVERT BELOW STORM DRAIN INVERT WHEN NECESSARY TO MAINTAIN MINIMUM 12" CLEARANCE UNDER CONFLICT SANITARY SEWER MAIN.
5. PRECAST CONCRETE MANHOLE TO BE IN COMPLIANCE WITH ASTM C-478.
6. WALL THICKNESS TO BE 5" MINIMUM FOR 48" INSIDE DIAMETER MANHOLES AND 6" MINIMUM FOR 60" INSIDE DIAMETER MANHOLES.
7. PROVIDE A MAXIMUM OF TWO LIFT HOLES PER SECTION. PLUG HOLES WATERTIGHT WITH RUBBER PLUGS AND GROUT AFTER INSTALLATION.
8. POURED IN PLACE BASE SLAB: REINFORCE WITH #5 REBAR @ 12" O.C. EACH WAY. ALL REBAR TO HAVE MIN. 1-1/2" COVER. CONCRETE TO BE CLASS A-3.
9. NO SEWER PIPE JOINTS ALLOWED INSIDE CONFLICT MANHOLE.

PRECAST CONCRETE CONFLICT MANHOLE

NOT TO SCALE

REFERENCE	CATEGORY	DATE	SHEET No.	DETAIL No.
200,302	DRAINAGE STRUCTURES	12/10	2 OF 2	DS_02