



NOTES:

1. INTERIOR DROP TO BE USED IN NEW MANHOLES.
2. SOLVENT WELD JOINTS ON ALL INSIDE PIPING AND FITTINGS.
3. MAINLINE TO PVC DROP CONNECTION SHALL BE MADE WITH APPROVED COUPLING.
4. PLACEMENT OF DROP CONNECTION SHALL NOT CONFLICT WITH THE PLACEMENT OF THE MANHOLE STEPS.
5. BOTTOM 90 DEGREE BEND TO BE AT 45 DEGREES WITH RESPECT TO THE DOWNSTREAM FLOW.
6. PRECAST CONCRETE MANHOLE TO BE IN COMPLIANCE WITH ASTM C-478.

SANITARY SEWER INTERIOR DROP MANHOLE

NOT TO SCALE

| REFERENCE | CATEGORY | DATE | SHEET No. | DETAIL No. |
|-----------|------------------|-------|-----------|------------|
| 200,802 | SANITARY SYSTEMS | 12/10 | 1 OF 1 | SS_04 |