



**NOTES:**

1. HYDRANT TO BE SET WITH BREAKABLE COUPLING APPROXIMATELY 3" ABOVE FINISHED GRADE.
2. STEAMER NOZZLE IS TO FACE ROADWAY UNLESS OTHERWISE NOTED.
3. CULVERT PIPE IS REQUIRED IF DITCH DEPTH (EDGE OF PAVEMENT TO BOTTOM OF DITCH) IS 18" OR MORE, OR HYDRANT VALVE FALLS WITHIN DITCH SLOPE.
4. SIZE OF CULVERT PIPE (RCP) IS TO BE APPROVED BY LOCALITY.
5. PROVIDE 6" MIN. COVER ON CULVERT AND 4" MIN. TOP SOIL AND SEED. FILL DITCH WITH CRUSHER RUN STONE.
6. TRACER WIRE REQUIRED.
7. ALL VALVES TO BE MJ.

**FIRE HYDRANT SETTING (TYPE II)**

NOT TO SCALE

REFERENCE	CATEGORY	DATE	DETAIL No.
200,801	WATER DISTRIBUTION	12/10	1 OF 1 WD_07