



DISTRIBUTION SYSTEM SUPPLY

Pipeline being chlorinated
and tested

NOTES:

1. ALL VALVES TO BE 2" BALL VALVES.
2. ALL PIPING SHALL BE PROTECTED FROM THE WEATHER DURING FREEZING CONDITIONS.
3. BACKFLOW PREVENTER SHALL BE INSTALLED AND TESTED IN ACCORDANCE WITH THE LOCALITY'S APPROVED CROSS CONNECTION CONTROL PROGRAM.
4. THE RPZ SHALL NOT BE INSTALLED IN A PIT OR AREA SUBJECT TO FLOODING.

TEMPORARY MANIFOLD FOR TEST AND CHLORINATION

NOT TO SCALE

REFERENCE (NONE)	CATEGORY WATER DISTRIBUTION	DATE 12/10	SHEET No. 1 OF 1	DETAIL No. WD_09
---------------------	--------------------------------	---------------	---------------------	---------------------