



- NOTE:**
1. COMPACT AROUND BRASS STANDPIPE TO 95% MODIFIED PROCTOR.
 2. SAMPLE STATION TO BE LOCATED OUTSIDE OF R/W CLEAR ZONE.

WATER SAMPLING STATION

NOT TO SCALE

REFERENCE 200,801	CATEGORY WATER DISTRIBUTION	DATE 12/10	SHEET No. 1 OF 1	DETAIL No. WD_13
----------------------	--------------------------------	---------------	---------------------	---------------------