



NOTES:

1. DUAL SERVICE REQUIRES PRIOR LOCALITY APPROVAL.
2. CONTRACTOR SHALL USE APPROVED BENDING TOOLS WHEN INSTALLING COPPER PIPE.
3. ALL DUCTILE IRON MAINS, SIX INCHES IN DIAMETER AND LARGER, MAY BE TAPPED WITHOUT SADDLES. WHERE PVC MAINS ARE PERMITTED BY LOCALITIES, THE CONNECTION TO A PVC MAIN MUST BE MADE WITH A TAPPING SADDLE. TAPPING SADDLES TO BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURERS SPECIFICATIONS. ALL SADDLES TO BE STAINLESS STEEL OR EPOXY COATED.
4. WHERE APPLICABLE, THE METER BOX IS TO BE LOCATED IN THE RIGHT-OF-WAY BETWEEN THE BACK OF CURB AND SIDEWALK.

SINGLE & DUAL SERVICE CONNECTIONS

NOT TO SCALE

REFERENCE	CATEGORY	DATE	DETAIL No.
200,801	WATER DISTRIBUTION	12/10	1 OF 1 WD_01