



NOTES:

1. HYDRANT TO BE SET WITH BREAKABLE COUPLING APPROXIMATELY 3" ABOVE FINISHED GRADE.
2. STEAMER NOZZLE IS TO FACE ROADWAY UNLESS OTHERWISE NOTED.
3. TRACER WIRE REQUIRED.
4. ALL VALVES TO BE MJ.

## FIRE HYDRANT SETTING (TYPE I)

NOT TO SCALE

REFERENCE	CATEGORY	DATE	DETAIL No.
200,801	WATER DISTRIBUTION	12/10	1 OF 1