



1. INTERIOR DROP TO BE USED IN NEW MANHOLES.
2. SOLVENT WELD JOINTS ON ALL INSIDE PIPING AND FITTINGS.
3. MAINLINE TO PVC DROP CONNECTION SHALL BE MADE WITH APPROVED COUPLING.
4. LOCATION OF DROP CONNECTION SHALL NOT CONFLICT WITH THE LOCATION OF THE MANHOLE STEPS.
5. BOTTOM 90 DEGREE BEND TO BE AT 45 DEGREES WITH RESPECT TO THE DOWNSTREAM FLOW.
6. PRECAST CONCRETE MANHOLE TO BE IN COMPLIANCE WITH ASTM C-478.
7. INTERIOR DROP SHALL BE NO MORE THAN 6 - INCHES FROM MANHOLE WALL.
8. ALL PVC PIPE AND FITTINGS SHALL BE SCHEDULE 40.

SANITARY SEWER INTERIOR DROP MANHOLE

NOT TO SCALE

REFERENCE	CATEGORY	DATE	SHEET No.	DETAIL No.
200,802	SANITARY SYSTEMS	6/16	1 OF 1	SS_04