



NOTES:

1. PROVIDE A CAPPED EXTENSION TO PROPERTY LINE PER LOCALITY REQUIREMENTS.
2. LATERAL PIPE SHALL BE THE SAME MATERIAL AS THE MAIN, UNLESS DUE TO SPECIAL CIRCUMSTANCES THE LOCALITY REQUIRES THE PIPE TO BE DUCTILE IRON. DUCTILE IRON SHALL REQUIRE A 6" STUB WITH MJ PLUG OR MJ CAP.
3. SEE PLANS FOR LOCATION OF CLEAN OUT.
4. TRACER WIRE SHALL BE INSTALLED CONTINUOUSLY FROM THE MAIN TO THE RIGHT OF WAY LINE DIRECTLY ON TOP OF THE PVC LATERAL. TRACER WIRE SHALL BE ATTACHED TO THE LATERAL.

SANITARY SEWER SERVICE CONNECTION

NOT TO SCALE

REFERENCE	CATEGORY	DATE	SHEET No.	DETAIL No.
200,802	SANITARY SYSTEMS	6/16	1 OF 1	SS_14