



1. HYDRANT TO BE SET WITH BREAKABLE COUPLING APPROXIMATELY 3" ABOVE FINISHED GRADE.
2. STEAMER NOZZLE IS TO FACE ROADWAY UNLESS OTHERWISE NOTED.
3. TRACER WIRE REQUIRED.
4. ALL VALVES TO BE MJ.
5. WHEN FIRE HYDRANT IS TO BE INSTALLED WITHIN EXISTING OR PROPOSED VDOT RIGHT-OF-WAY, HYDRANTS SHALL BE LOCATED IN ACCORDANCE WITH VDOT REQUIREMENTS.
6. HYDRANT(S) SHALL BE PAINTED IN ACCORDANCE WITH LOCALITY REQUIREMENTS.

FIRE HYDRANT SETTING (TYPE I)

NOT TO SCALE

REFERENCE	CATEGORY	DATE	SHEET No.	DETAIL No.
200,801	WATER DISTRIBUTION	6/16	1 OF 1	WD_06