



NOTE:

1. COMPACT AROUND BRASS STANDPIPE TO 95% MODIFIED PROCTOR.
2. SAMPLE STATION TO BE LOCATED OUTSIDE OF R/W CLEAR ZONE.

WATER SAMPLING STATION

NOT TO SCALE

REFERENCE
200, 801

CATEGORY
WATER

DATE
6/16

SHEET No.
1 OF 1

DETAIL No.
WD_13