

FOG Hauler Certification Test

1. The appropriate cleaning schedule of a GCD is required to help ~~and kitchen BMPs help~~ ~~to~~ eliminate FOG discharge into the sanitary sewer system.
 - a. True
 - b. False
2. It is completely legal to discharge FOG directly into the sanitary sewerage or stormwater system. ~~FOG should never be discharged directly to the sanitary sewer or stormwater system.~~
 - a. True
 - b. False
3. A sludge judge can be used to measure the estimated amount of FOG including grease and settled solids in the GCD prior to cleaning. If over 25% the FSE should be informed and the GCD should be cleaning more frequently. ~~estimate the amount of FOG wastes and settled solids prior to cleaning.~~
 - a. True
 - b. False
4. FSE customers will not pass their FOG inspection without proper documentation of the GCD cleaning which is why proper documentation and accurate measurements are critical to customer service. ~~It is good customer service to inform your clients of the structural condition and capacity of their GCDs.~~
 - a. True
 - b. False
5. Decanting, discharging of the removed waste back into the GCD -is prohibited in Hampton Roads.
 - a. True
 - b. False
6. A hydro-mechanical grease interceptor (HGI) and an Automatic Grease Removal Device (AGRD) may be cleaned by the FSE employees without the approval of the locality FOG Program. ~~Some grease traps can be cleaned by Food Establishment employees.~~
 - a. True
 - b. False
7. A Sludge Judge measurement should be taken from the in-let side of the Gravity Grease Interceptor (GGI). ~~Food Establishment employees may clean grease traps under _____ gallons per minute (gpm) and dispose of the waste in the trash.~~
 - a. True
 - b. False²⁵
 - c. ~~50~~
 - d. ~~100~~

8. In most localities, grease haulers must have a permit from an approval disposal facility.
~~Food Establishments and haulers should anticipate seasonal changes in business.~~
 - a. True
 - b. False
9. AGRDs must always be plugged into an electrical supply and cleaned as recommended by the manufacturer.
~~GCD inspection findings should be recorded on the cleaning manifest.~~
 - a. True
 - b. False
10. GCDs with more than one compartment must should have all compartments cleaned thoroughly.
If a compartment is not accessible, notify the FSE that there is a problem.
 - a. True
 - b. False
11. Hydro-mechanical Grease Interceptors (HGIs) were previously referred to grease traps.
~~Grease traps should be easily accessible, since they require frequent cleaning.~~
 - a. True
 - b. False
12. If the GCD accumulates more than 25% grease and settled solids between cleanings, the cleaning schedule should be increased.
~~changed.~~
 - a. True
 - b. False
13. Hot water, acids, caustics, solvents, enzymes or emulsifiers ~~and solvents~~ are ok to use when cleaning GCDs.
 - a. True
 - b. False
14. An FSE must keep cleaning/maintenance records on site for three (3) years.
~~Grease traps over 50 gpm must be cleaned by an approved grease hauler.~~
 - a. True
 - b. False
15. The manifest left with the FSE should include a condition of the GCD and sludge judge measurements.
~~The record of volume removed should include the water removed.~~
 - a. True
 - b. False