

January 18th, 2017
HRPDC FOG Committee
Fryer Boil Out Disposal

Based on the information provided to HRSD and to the HRPDC FOG Subcommittee; waste water generated from the use of any Fryer Boil Out cleaning product must not pass through a grease trap as defined by the Hampton Roads Planning District Committee (HRPDC) to be a grease removal device generally located inside an FSE and under 50 GPM. The cleaner has the potential to act as a degreaser to allow FOG to pass through a grease trap and into the sewerage system.

All agree to instruct the user that such wastewater is to be disposed of via mop sink / floor drain or other drain that does not lead to a grease trap.

All Industrial Customers shall submit to HRSD, in writing, a request of approval for any and all products to be discharged to the sanitary sewerage system. Product requests must be accompanied by a Material Safety Data Sheet or Safety Data Sheet (MSDS/SDS). Along with an approval of such products, HRSD will stipulate the user must also be granted approval from the local municipality or county before using the product.